

Account: _____

Membership: _____

**Cross Timbers Water Supply Corporation PWS ID: 0610020
2032 E Hickory Hill Road, Argyle, Texas 76226, (940) 584-0780**

CUSTOMER SERVICE INSPECTION CERTIFICATE

Reason for Inspection

- New Construction []
- Existing service where contaminant hazards are suspected..... []
- Major renovation or expansion of distribution facilities..... []

I, _____, upon inspection of the private water distribution connected to the aforementioned public water supply do hereby certify that, to the best of my knowledge:

- | Compliance | Non-Compliance | |
|------------|----------------|---|
| [] | [] | (1) No direct connection between the public drinking water supply and a potential source of contamination exists. Potential sources of contamination are isolated from the public water system by an air gap or an appropriate backflow prevention assembly in accordance with Commission regulations. |
| [] | [] | (2) No cross-connection between the public drinking water supply and a private water system exists. Where an actual air gap is not maintained between the public water supply and a private water supply, an approved reduced pressure-zone backflow prevention assembly is properly installed and a service agreement exists for annual inspection and testing by a certified backflow prevention assembly tester. |
| [] | [] | (3) No connection exists which would allow the return of water used for condensing, cooling or industrial processes back to the public water supply. |
| [] | [] | (4) No pipe or pipe fitting which contains more than 8.0% lead exists in private water distribution facilities installed on or after July 1, 1988. |
| [] | [] | (5) No solder or flux which contains more than 0.2% lead exists in private water distribution facilities installed on or after July 1, 1988. |

Where a serious threat to the public health or to the public drinking water supply exists, CTWSC shall not provide water service or restore service to a private plumbing facility until the above conditions are determined to be in compliance.

I further certify that the following materials were used in the installation of the private water distribution facilities:

- Service lines:** Lead [] Copper [] PVC [] Other []
- Solder:** Lead [] Lead Free [] Solvent Weld [] Other []

I recognize that this document shall become a permanent record of the aforementioned Public Water System and that I am legally responsible for the validity of the information I have provided.

Remarks: _____

Title / Registration Number

Date

Signature of Inspector

Printed Name